



659(*) SW4 0.6/1 kV

TCu/EPR/ZH/TPBWB/ZH

BS 6883

Halogen-free, flame retardant, offshore & shipboard power cables with elastomeric insulation and sheath, with tinned phosphor bronze wire braid

CONSTRUCTION

Conductors	Tinned annealed circular stranded copper class 2 acc. to BS EN 60228
Insulation	Halogen-free elastomer compound EPR type GP4 acc. to BS 7655-1.2
Core identification	Red or black
Inner sheath	Halogen-free, heat-resistant, oil-resisting and flame-retardant elastomer compound type SW4 acc. to BS 7655-2.6
Screen	Tinned phosphor bronze wire braid
Separator	Separator, suitable tape between the braid and outer sheath
Outer sheath	Halogen-free, heat-resistant, oil-resisting and flame-retardant elastomer compound type SW4 acc. to BS 7655-2.6
Colour of outer sheath	Black



CHARACTERISTIC

Maximum conductor operating temperature:	+90°C	
Lowest ambient temperature for fixed installation:	-40°C	
Lowest installation temperature:	-15°C	
Minimum bending radius:	Overall diameter of cable (D)	Minimum bending radius
	< 25 mm	4 D
	> 25 mm	6 D
	D – overall diameter of cable	

659(*) SW4 0.6/1 kV

TCu/EPR/ZH/TPBWB/ZH

BS 6883

Fire performance

Flame retardant:	IEC 60332-3-22 Category A
Smoke emission:	BS EN 61034-2, IEC 61034-2
Corrosive gas emission:	BS EN 50267-2-1, IEC 60754-1: type SW4 cables \leq 0.5% HCl
UV resistant:	UL 1581

Applications

Armoured instrumentation cable for fixed installations in all areas including accommodation and on open deck in ships and offshore units where halogen-free cable protection is required.

Standard length cable packing:	1,000 m on drums Other forms of packing and delivery are available on request
--------------------------------	--

Number and cross-sectional area of conductor	Class of the conductor	Nominal thickness of insulation	Nominal thickness of inner sheath	Diameter of wires in braid	Nominal thickness of outer sheath	Approximate overall diameter of cable	Approximate net weight of the cable
n × mm²		mm	mm	mm	mm	mm	kg/km
1 × 1	2	0.8	1	0.3	1.1	8.5	137
1 × 1.5	2	0.8	1	0.3	1.1	8.8	145
1 × 2.5	2	0.8	1	0.3	1.1	9.2	160
1 × 4	2	1	1	0.3	1.1	10.2	190
1 × 6	2	1	1	0.3	1.1	10.8	219
1 × 10	2	1	1	0.3	1.2	11.9	280
1 × 16	2	1	1.1	0.3	1.2	13.3	371
1 × 25	2	1.2	1.2	0.3	1.3	15.4	519
1 × 35	2	1.2	1.2	0.3	1.4	16.8	644
1 × 50	2	1.4	1.3	0.3	1.4	18.5	789
1 × 50*	5	1.4	1.3	0.3	1.4	18.7	798
1 × 70	2	1.4	1.3	0.3	1.5	20.4	1,029
1 × 95	2	1.6	1.4	0.3	1.6	23.2	1,372
1 × 120	2	1.6	1.5	0.3	1.7	25.1	1,635
1 × 150	2	1.8	1.6	0.3	1.8	27.4	1,975

659(*) SW4 0.6/1 kV

TCu/EPR/ZH/TPBWB/ZH

BS 6883

Number and cross-sectional area of conductor	Class of the conductor	Nominal thickness of insulation	Nominal thickness of inner sheath	Diameter of wires in braid	Nominal thickness of outer sheath	Approximate overall diameter of cable	Approximate net weight of the cable
1 × 185	2	2	1.7	0.45	1.9	30.7	2,520
1 × 185*	5	2	1.7	0.45	1.9	31.3	2,438
1 × 240	2	2.2	1.8	0.45	2	34.1	3,184
1 × 300	2	2.4	1.9	0.45	2.1	37.2	3,877
1 × 400	2	2.6	2	0.45	2.3	41.1	4,814
1 × 500	2	2.8	2.2	0.45	2.5	45.7	6,042
1 × 630	2	2.8	2.3	0.45	2.6	50	7,609

*) Based on standard

Please refer to technical section for additional information relating to these cables.

The information contained in this document, including the tables and drawings, are provided for illustrative purposes only and not a commercial offer; nor may it constitute the basis for pursuing any claim against TELE-FONIKA KABLE SA. The suitability of any product including properties, should be made by a qualified person; having already gained the appropriate permissions and documentation, to ensure compliance with any applicable law or regulation.